

# Product sheet



## LEGRAND

Surge protective device - protection of main distribution board - T1+T2 - limp 12.5 kA/pole - 4P

REF. 412273 | EAN. 3414970517425

> [Visit e-catalogue](#)

## Product characteristics

- T1+T2

## Recommendation / Restriction

- "To provide correct protection, a lightning arrester is recommended: - at the origin of each installation (mandatory depending on the type and location of the installation to be protected, - at the origin of divisional switchboards: secondary protection or fine protection of sensitive equipment, - on all outputs of external electrical circuits (supply to secondary buildings, external lighting or external electrical panels, etc.). A communication network arrester should always be installed to protect communication equipment in the presence of a lightning arrester on the low-voltage network."

## Documentation

### TECHNICAL DOCUMENTATION


 EXB20026\_TG\_Surge\_Protective\_Devices\_EN.pdf | PDF (8.37Mo)

 F02060EN\_05.pdf | PDF (0.62Mo)

 F02060FR\_06.pdf | PDF (0.61Mo)

→ LE07561AA\_6.pdf | PDF (0.53Mo)

### CAD & Design specs / BIM

 412233.dwg | DWG (0.37Mo)

### CATALOGUE PAGE & OTHERS

 ex223001\_0088-0089.pdf | PDF (0.16Mo)

 ex223001\_0087.pdf | PDF (0.12Mo)

 ex223001\_0084.pdf | PDF (0.08Mo)

### Agreements & Certificates

 OC / CB-AT 5098 | (0.22Mo)